



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号 CE20.2356
Certificate No.

产品名称 Name of Product	压力变送器
型号及规格 Type of Product	MPM489-B1
防爆标志 Marking	Ex ia II C T6 Ga
技术文件 Technical Documents	Q/VHD M011-2017
图号 Drawing No.	MS2.580.023、MS2.580.023-1、MS2.580.023P2、MS2.580.023-1P2
备注 Note (s)	

1. 本安参数: $U_i: 28VDC$, $I_i: 93mA$, $P_i: 0.65W$, $C_i: 0.012 \mu F$, $L_i: 0mH$ 。
2. 本证可代表产品型号: MPM489-B1、MPM489-B2。
3. 产品使用环境温度: MPM489-B1 ($-30^{\circ}C \leq T_a \leq +60^{\circ}C$);
MPM489-B2 ($-20^{\circ}C \leq T_a \leq +60^{\circ}C$)。
4. 此产品必须与安装在安全区的关联设备连接, 关联设备参数见使用说明书。
5. 产品使用环境温度变更备案。

经对上述产品图样及技术文件的审查和样品的检验, 其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010

GB 3836.4-2010

发给: 麦克传感器股份有限公司
Issued to:

本证失效日期: 2025-06-16

Date of Expire:

发证日期: 2020-10-26

Date of Issue:

中心印章
Center seal



中心主任
Director

国家防爆产品质量监督检验中心 (天津)
(石油和化学工业电气产品防爆质量监督检验中心)
National Ex-Product Quality Supervision and Inspection Center (TianJin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

邮政编码: 300131 电话/传真: 022-26651066 / 26689116

Center Add: No 85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail: pcec@pcec.com.cn

http://www.pcec.com.cn